

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING NO:** 3161-0935:104

Page 1 of 1

**CATEGORY:** Air Diffusers

**LISTEE:** Nailor Industries, 4714 Winfield, Houston TX 77039  
Contact: John Young (281) 590-1172

**DESIGN:** Models 4010 through 4090, and 4410 through 4480 air diffusers. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as air diffusers for use in noncombustible fire-rated ceiling/floor or ceiling/roof designs with acoustical tile and exposed T-Bar grids having up to 3-hours fire-rating.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager